CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3774-0923:102 Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Securitron Magnalock, 550 Vista Blvd., Sparks, NV 89434

Contact: *Eric Strauss (775) 355-5625

DESIGN: Models EXD-1 and EXD-1F exit delay systems. Unit consists of the following

> subassemblies: BPS-12, -1, -3, -4.5, -6, -9, -15, BPS-24, -1, -2, -3, -4, -6, -10 power supplies, MK or MKN mortise keyswitch, TSB-1, TSB-3, TSB-3B, 3100, 3300, 3600, 3700, LMS-1, LML-1, -2, TSH-BK, -CL, MXD-32, -62 exit device, TDM, TDMT, XDT logic timers and Series 32, 34, 62 and 82 locking device and LCP Lock Control Panel. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 120VAC, Output: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances,

NFPA 101 and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electric special egress-control device when installed in accordance to Uniform

> Building Code Section 1004.5. Model EXD-1 is intended for installation on non-fire rated doors. Model EXD-1F is intended for installation on wood or metal fire rated doors.

Authority having jurisdiction shall be consulted prior to installation.

NOTE: Both models may be used in conjunction with a separately listed fire alarm control panel,

however, the units must be connected via the panels dry relay contacts designated a "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts

is NOT approved.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 11, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager